



## Proposed Code Change

State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

### FOR OFFICE USE ONLY

Received 6/29/09

Code 48.12-09

#### INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title 2009 Indiana Residential Code		Edition First Edition
Section number and title R408.1 Ventilation		Page 1 of 1
Proponent Craig Wagner	Title Chief Building Inspector/ IABO Code Comm. Member	
Address 220 W Van Buren St, Columbia City IN 46725		Phone 260-248-3111
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>Change the last sentence of R408.1 as follows: ...opening shall be within <del>3</del> <u>4</u> feet...</p>		
REASON AND FISCAL IMPACT		
<p>This proposal brings forward an amendment from the 2005 InRC that allows the corner vents in a crawlspace wall to be spaced four feet from the corner to more easily fit into masonry block construction.</p>		
<b>Fiscal impact:</b> There is no additional cost to construction.		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		

